

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report
 Division Name: P.H.Division, Ara

District Name: Bhojpur

Month:- January-2020

Sl. No.	Block	Panchyat	Village	Name of Habitation	Location of Source	Parameters														Remarks	
						pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As		Total Coli
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
1	Ara	Bampali	Bampali		Gyan Jyoti Awasiya Vidyalaya, Bampali	7.2	2	460	302	134	42	15	22	150	0.2	BDL	5	0.1	NT	-Ve	Safe
Desirable Limit*						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-	
Permissible Limit* In absence of alternate source						NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	-	

In case of new please indicate in column 15
 NT= Not Tested

Celipi Jain
Principal
 Gyan Jyoti Awasiya Vidyalaya
 Bampali, Ara

[Signature]
 Chemist 24/01/20
 P.H.Division, Ara
 District Level Water Testing Laboratory
 P.H. Division, Ara